

## ELEVATION

## NOTES:

- THIS INSTALLATION MAY BE REPLACED BY A FIRE HYDRANT WHERE APPROVED BY DENVER WATER FOR 16" AND 20" MAINS.
- 2. MEG-A-LUG IS AN ACCEPTABLE ALTERNATIVE TO RODDING.
- THE DISTANCE BETWEEN RUNGS, CLEATS, AND STEPS SHALL NOT EXCEED12 INCHES AND SHALL BE UNIFORM THROUGHOUT THE LENGTH OF THE LADDER.

DENVER WATER 1600 West 12th Avenue Denver, Colorado 80204 Phone(303)628-6000 Telecopier No.(303)628-68	51
TRANSMISSION MAIN BLOW-OFF INSTALLATION	
Scale: _ <u>NONE</u>	Date: _JUNE_1995
Drawn: _ C.B.B Tr:	Ck:
Approved:	Dr. 127 No. 35

REVISED 5-2002